Part No. 6857

# LASER®

# **Ultrasonic Cleaner**

13L - Euro Plug

Instructions





www.lasertools.co.uk

#### Introduction

Ultrasonic cleaning is a thorough, fast and safe way of cleaning small and difficult to clean parts. The ultrasonic cleaner uses high frequency sound waves to create millions of tiny bubbles in the liquid solution. These bubbles expand and collapse rapidly, the energy released creating an intense scrubbing action which is equally as effective on unseen small crevices and blind holes as on visible surfaces. The dirt is loosened and removed from any surface that the liquid touches. This action is referred to as 'acoustic cavitation' and occurs thousands of time per second to quickly produce clean parts.

Ultrasonic cleaners are most effective when used to clean hard materials such as metals, glass, stone, ceramic and dense, hard plastics. It will also clean jewellery with hard, natural stones like diamond, sapphire, ruby, garnet, etc, but is not suitable for soft gemstones such as pearls, opal, emerald, tanzanite, malachite, turquoise, lapis and coral.


As ultrasonic cleaning relies on the impact of the cavitation bubbles against a hard surface to erode soiling, it is not an effective cleaning method on soft materials such as rubber, cloth, polystyrene foam or similar.

The large 13 litre capacity of the fluid tank enables the cleaning of automotive components such as dismantled carburettors, brake parts, etc.


Ultrasonic cleaning does not sterilise.

### **Components**

| Ref.         | Description                |
|--------------|----------------------------|
| Α            | Fluid Tank                 |
| В            | Parts Basket               |
| С            | Heater Control             |
| D            | Heater Indicators          |
| E            | Timer Indicators           |
| F            | Timer Control              |
| G            | Ultrasonic Power<br>Switch |
| Н            | Drain Tap                  |
| 1            | Power Lead<br>Socket       |
| J            | Main Power<br>Switch       |
| Not pictured | Lid                        |
| Not pictured | Power Cord                 |



#### **Controls**



www.lasertools.co.uk

# **Instructions**

#### **Operation**

- 1. Before use, please fully read and understand these instructions, particularly the **Precautions** section (below).
- 2. Place the ultrasonic cleaner on a flat, clean surface where there is adequate ventilation for the cooling fans.
- 3. Refer to Fig 1: Ensure the power lead is plugged securely into the socket at the rear of the cleaner (I).
- 4. Check that the drain tap (**H**) is in the closed position, then carefully fill at least 2/3 of the tank with clean water or cleaning solution. Fill to a level where the tank will not overflow when the item(s) to be cleaned are added. The cleaner is now ready for use.
- 5. Place the item(s) to be cleaned in the parts basket (**B**) and lower the basket into the tank. The basket will rest securely on the bottom of the tank.
- 6. Replace the lid back on the tank.
- 7. Switch on the mains power supply socket. Then switch on the **main power switch** at the rear of the unit (adjacent to the power lead socket).
- 8. Set the Timer (**F**) to the desired length of cleaning time (a maximum of 30 minutes). This also switches the ultrasonic cleaner ON. Do not run the ultrasonic cleaner continuously for more than 30 minutes.
- 9. Note: for cleaning of delicate parts, the ultrasonic power switch (**G**) can be set to the "soft" setting.
- 10. For heavily soiled parts or items, the fluid can be heated. Set the Heater Control (C) to the desired temperature (13 temperature settings from 20° to 80°C). The heater temperature indicators (D) will rise until the pre-set temperature has been reached. Best results are usually between 40° 60° C.
- 11. When the Timer returns to zero and the cleaning is completed, return the Heater Control to the OFF position. Then switch off the main power switch at the rear of the unit.
- 12. Let the water or cleaning solution **cool down** before draining and cleaning the ultrasonic cleaner in preparation for its next use. **The cleaner will be damaged if hot fluid is immediately drained off after a cleaning operation.**

# Instructions

## **Cleaning Fluids & Solutions**

For general cleaning it is satisfactory to use just deionised, demineralised or distilled water and a warm temperature setting ( $40^{\circ}-50^{\circ}$ C). For enhanced cleaning a few drops of standard washing up liquid (or similar non-acidic detergent) can be added. Proprietary specialist solutions are also available designed for ultrasonic cleaners.

The effectiveness of cleaning solutions will deteriorate over time and use, especially where heavily soiled items have been cleaned. Regularly change the fluid and carefully wash and dry the inside of the fluid tank after every use. Do not use corrosive or abrasive cleaning products.

#### **Precautions**











- Read and understand these instructions before use.
- Do not operate if the tank is less than 2/3 full.
- Ensure power is disconnected from the mains before adding or removing fluid.
- Do not rest items on the base of the bath always use the basket.
- When cleaning items for the first time, test a sample piece before cleaning the remainder.
- Do not place hands or fingers in the bath while the machine is switched on. Contact exposure to ultrasonic cavitation may cause tissue and bone damage.
- Do not use any fluids which could damage the stainless steel bath, for example acids or strong alkaline.
- Solvents or flammable liquid solutions should never be used in the ultrasonic cleaner.
- Do not run the ultrasonic cleaner continuously for more than 30 minutes.
- Let the fluid cool down and disconnect power from the mains before draining off.
- Always clean bath after use.
- Water-based detergent solutions should be made up with deionised, demineralised or distilled water as calcium carbonate and other impurities in tap water can reduce the cleaning properties and even cause deposits and staining on the items being cleaned.
- Cleaning solutions should be changed regularly. Dirty solutions will re-deposit soils on the items being cleaned and can coat the bottom of the tank reducing ultrasonic activity.

# **Specifications**

Cleaner/tank material: SUS304 stainless steel

• Timer setting: 0-30 minutes adjustable

• Temperature setting: 20°C-80°C adjustable

· CE, FCC, RoHS tested and approval

• Ultrasonic frequency: 40kHz

• Power (ultrasonic): 300W

• Power (heating): 400W

Tank capacity: 13 litres

• Basket size: (mm) 290 × 275 × 92.5 (L × W × H)

Tank size: (mm)
330 × 300 × 150 (L × W × H)

Overall size: (mm) 360 × 330 × 310 (L × W × H)

• Unit weight: 9.86kg

UK plug version also available - Part No. 6164

Our products are designed to be used correctly and with care for the purpose for which they are intended. No liability is accepted by the Tool Connection for incorrect use of any of our products, and the Tool Connection cannot be held responsible for any damage to personnel, property or equipment when using the tools. Incorrect use will also invalidate the warranty.

If applicable, the applications database and any instructional information provided has been designed to offer general guidance for a particular tool's use and while all attention is given to the accuracy of the data no project should be attempted without referring first to the manufacturer's technical documentation (workshop or instruction manual) or the use of a recognised authority such as Autodata.

It is our policy to continually improve our products and thus we reserve the right to alter specifications and components without prior notice. It is the responsibility of the user to ensure the suitability of the tools and information prior to their use.











6857\_Instructions\_V2



ONNECTION

www.lasertools.co.uk



#### Guarantee

If this product fails through faulty materials or workmanship, contact our service department direct on: +44 (0) 1926 818186. Normal wear and tear are excluded as are consumable items and abuse.

